

Certificate of Product Approval

Certificate Number: 568a

Issue: 18

RAMCRO S.p.A.

Via Marzorati 15
20014 Nerviano
Milan
Italy

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Ramfirecro-F3 FIRE PLANET

Standards (see Appendix for details)

BS 6387:2013 (CWZ)
EN 60754-1:2014
EN 61034-2:2005+A2:2020
EN 50200:2015 (Class PH120)
EN 50200:2015 Annex E (30 minutes)
EN 60754-2:2014

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Certification Manager

9 November 2023

Date of Issue

27 October 2003

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



bre

Appendix to Certificate No: 568a RAMCRO S.p.A.

Issue: 18

| Product name | | | | | | | LPCB Ref. No. |
|--------------------------------|-------------------|---------|------------|------------|------------|----------|------------------|
| Ramfirecro-F3 FIRE PLANET | | | | | | | 568a/02 |
| Nominal csa of conductor (mm²) | Core Construction | BS 6387 | EN 60754-1 | EN 60754-2 | EN 61034-2 | EN 50200 | EN 50200 Annex E |
| 1.5 ^(1,2) | 2, 3 & 4 | C,W,Z | <0.5% HCl | Complies | >60% | PH 120 | 30 minutes |
| 2.5 ^(1,2) | 2, 3 & 4 | C,W,Z | <0.5% HCl | Complies | >60% | PH 120 | 30 minutes |
| 4 ⁽¹⁾ | 2, 3 & 4 | C,W,Z | <0.5% HCl | Complies | >60% | PH 120 | 30 minutes |

Uo/U 300/500V

Notes:

1. Stranded conductors only.
2. Solid conductor only.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha
Certification Manager

9 November 2023
Date of Issue

27 October 2003
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.



bre