

Certificate of Product Approval

Certificate Number: 568a

Issue: 17

RAMCRO S.p.A.

Via Marzorati 15
20014 Nerviano
Milan
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Ramfirecro-F3 FIRE PLANET

Standard(s) (see Appendix for details)

BS 6387:2013 (CWZ)
EN 60754-1:2014
EN 61034-2:2005+A2:2020
EN 50200:2015 (Class PH120)
EN 50200:2015 Annex E (30 mins)
EN 60754-2:2014
EN 60332-3-24:2009
EN 60332-3-25:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha

Signed for BRE Global Ltd.

Obada Piracha

Certification Manager

13 July 2022

Date of Issue

27 October 2003

Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 568a RAMCRO S.p.A.

Issue: 17

Product name									LPCB Ref. No
Ramfirecro-F3 FIRE PLANET									568a/02
Nominal csa of conductor (mm ²)	Core Construction	BS 6387	EN 60754-1	EN 60754-2	EN 61034-2	EN 50200	EN 50200 Annex E	EN 60332-3-24	EN 60332-3-25 See note 3
1.5 ^(1,2)	2, 3 & 4	C,W,Z	<0.5% HCl	Complies	>60%	PH 120	30 minutes	Complies	Complies
2.5 ^(1,2)	2, 3 & 4	C,W,Z	<0.5% HCl	Complies	>60%	PH 120	30 minutes	Complies	Complies
4 ⁽¹⁾	2, 3 & 4	C,W,Z	<0.5% HCl	Complies	>60%	PH 120	30 minutes	Complies	Complies

Uo/U 300/500V

Notes:

1. Stranded conductors only.
2. Solid conductor only.
3. EN 60332-3-25 approval is only applicable to cables with an overall diameter of equal to or less than 12mm.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Obada Piracha
Signed for BRE Global Ltd.

Obada Piracha
Certification Manager

13 July 2022
Date of Issue

27 October 2003
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.

