

Certificate of Product Approval

Certificate Number: 568e

Issue: 06

RAMCRO S.p.A.

Via Marzorati
15 - 20014 Nerviano
Nerviano
Milan
20014
Italy



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Ramfirecro-F3 FIRE GROUND

Standard(s) (see Appendix for details)

BS 6387:2013 (CWZ)
EN 60754-1:2014
EN 61034-2:2005+A1:2013
EN 60754-2:2014
EN 60332-3-24:2009
EN 60332-1-2:2004

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

11 September 2018
Date of Issue

27 May 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 568e RAMCRO S.p.A.

Issue: 06

Product name							LPCB Ref. No.
Ramfirecro-F3 FIRE GROUND							568e/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 6387 (see note 2)	EN 60754-1	EN 61034-2	EN 60754-2	EN 60332-3-24	EN 60332-1-2
1.5 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
2.5 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
4 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
6 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
10 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
16 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies
25 ⁽¹⁾	2,3,4 & 5	CWZ	<0.5% HCI	>60%	Complies ⁽³⁾	Complies	Complies

Uo/U 600/1000 V

Notes:

1. Class 5 stranded conductor only.
2. The Ramfirecro-F3 FIRE GROUND range with diameters greater than 20mm were tested in accordance with clause 17.6.2 and annex I of BS 7846:2015.
3. Tested to general method given in EN 60754-2:2014.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

11 September 2018
Date of Issue

27 May 2016
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.


