Certificate of Compliance

Certificate Number(s):

UL-US-26137277-0

Report Reference:

E556547-20261015

Issue Date:

2026-10-16

Issued to:

RAMCRO SPA
VIA MARZORATI 15, NERVIANO, MI, 20014, IT

This certificate confirms that representative samples of:

ZOYR - Reaction to Fire and Fire Resistance of Cables Evaluated in accordance with International Standards

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

BS 6387:2013
EN 50200:2015
IEC 60331-21:1999
DS/EN 60754-1, Issue Date: 2014-6-2, Revision Date: 2020-3-11
EN 60754-2:2020
EN 61034-2:2020

Additional Information:
See UL Product iQ® at https://iq.ulprospector.com for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.

CERTIFICATE OF COMPLIANCE

Certificate number(s): UL-US-26137277-0
Report reference: E556547-20261015
Issue Date: 2026-10-16

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Cables Evaluated International Standards

Model(s): RAMFIRECRO-F3 FIREPLANET EVO 300/500 V, 2, 3 & 4 Core 1.5 & 2.5 SQ.MM *Cu Class 1 / Silicon Insulated / Overall Silicon Tape / Aluminium mylar tape/ Drain wire/ Polyolefin Sheathed Fire-resistant Cables*

Model(s): RAMFIRECRO-F3 FIREPLANET EVO 300/500 V, 2, 3 & 4 Core 1.5, 2.5 & 4 SQ.MM *Cu Class 2 / Silicon Insulated / Overall Silicon Tape / Aluminium mylar tape/ Drain wire/ Polyolefin Sheathed Fire-resistant Cables*

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at https://www.ul.com/contact-us.

© 2026 UL LLC. All rights reserved.